
AMENDMENT TO RENEWABLE ENERGY APPROVALNUMBER 2189-8NQPZ5
Issue Date: November 15, 2013

South Glengarry General Partner 1 Inc. and South Glengarry General Partner 2 Inc. operating
as South Glengarry Solar Farm Partnership
620 Righters Ferry Rd
Bala Cynwyd, Pennsylvania
USA 19004

Site Location: 18423 County Road 19 and 18461 County Road 19
Lot 40, 41, 41a, Concession 5IL
South Glengarry Township, United Counties of Stormont, Dundas and Glengarry
K0C 2J0

You are hereby notified that I have amended Approval No. 2189-8NQPZ5 issued on December 19, 2011 for a Class 3 solar facility , as follows:

A. The description of the Class 3 solar facility on page 1 of the Approval is deleted and replaced with the following:

- The construction, installation, operation, use and retiring of a Class 3 solar facility with a total name plate capacity of up to 10 megawatts.

B. The following definition of Acoustic Assessment Report is added to the definitions of the Approval:

- 1a. "Acoustic Assessment Report" means the report included in the Application and entitled "Acoustic Assessment Report - Penn Energy - S. Glengarry_ St. Lawrence-1 Solar Farm" dated May 10, 2013, prepared by Petr Chocensky and Ian Bonsma, Howe Gastmeier Chapnik Limited; and includes additional correspondence submitted up to October, 2013;

C. The definition of the Application on page 2 of the Approval is deleted and replaced with the following:

3. "Application" means the application for a Renewable Energy Approval dated July 5, 2011, and signed by Max Frable, Project Manager/ REA Coordinator, Penn Energy Renewables, Ltd., and all supporting documentation submitted with the application, including amended documentation submitted up to December 13, 2011; and as further amended by the application for a Renewable Energy Approval, dated May 18, 2012, and signed by Max Frable, Project Manager/REA Coordinator, Penn Energy Renewables, Ltd. and all supporting documentation submitted with the application, including amended documentation submitted up to July 10, 2012; and as further amended by the application dated June 7, 2013 and signed by Mr. Glen Tomkinson, Project Manager/REA Coordinator, South Glengarry General Partner 1 Inc. and South Glengarry General Partner 2 Inc., operating as South Glengarry Solar Farm Partnership, and all supporting documentation submitted with the application, including amended documentation submitted up to the date this amendment is issued;

D. Condition No. 8 on page 5 of the Approval is deleted and replaced with the following:

8. Construction and installation of the *Facility* must be completed within three (3) years of the later of:
- (1) the date this *Approval* is issued; or
 - (2) if there is a hearing or other litigation in respect of the issuance of this *Approval*, the date that this hearing or litigation is disposed of, including all appeals.

E. Schedule A is deleted and replaced with the following Schedule A:

SCHEDULE A

Noise Specifications and Coordinates of the Equipment in UTM, Z18-NAD83 projection:

Source ID	Source Description	Maximum Sound Power Level [dBA]	Height [m]	UTM Coordinates	
				Easting	Northing
NS-01	Inverter House MV1	88	1.5	524587	4994981
NS-02	Inverter House MV2	91	1.5	524595	4995076
NS-03	Inverter House MV3	91	1.5	524627	4994781
NS-04	Inverter House MV4	91	1.5	524638	4994914
NS-05	Inverter House MV5	91	1.5	524652	4995066
NS-06	Inverter House MV6	91	1.5	524754	4995247
NS-07	Inverter House MV7	91	1.5	524896	4994772
NS-08	Inverter House MV8	91	1.5	524908	4994905
NS-09	Inverter House MV9	91	1.5	524921	4995057
NS-10	Inverter House MV10	91	1.5	524968	4994933
NS-11	Transformer 1 MVA (MV1)	69	1.5	524592	4994980
NS-12	Transformer 1 MVA (MV2)	69	1.5	524600	4995075
NS-13	Transformer 1 MVA (MV3)	69	1.5	524622	4994782
NS-14	Transformer 1 MVA (MV4)	69	1.5	524634	4994914
NS-15	Transformer 1 MVA (MV5)	69	1.5	524647	4995067
NS-16	Transformer 1 MVA (MV6)	69	1.5	524750	4995247
NS-17	Transformer 1 MVA (MV7)	69	1.5	524901	4994772
NS-18	Transformer 1 MVA (MV8)	69	1.5	524913	4994905
NS-19	Transformer 1 MVA (MV9)	69	1.5	524926	4995056
NS-20	Transformer 1 MVA (MV10)	69	1.5	524963	4994933
NS-21	Transformer 10 MVA	88	2	525013	4994843

F. Schedule C is deleted and replaced with the following Schedule C:

**SCHEDULE C
Facility Description**

The Facility shall consist of the construction, installation, operation, use and retiring of the following:

- (a) Ten (10) ground mounted arrays of photovoltaic (PV) modules or panels with a total name plate capacity of up to 10 megawatts (AC) or 12 megawatts (DC), with each array consisting of approximately 4000-4500 PV modules and one (1) pad-mounted 1 Megavolt-ampere (MVA) three-phase, liquid filled transformer and two (2) 500 kilowatt inverters;
- (b) one (1) 10 MVA step up power transformer substation; and
- (c) associated ancillary equipment, systems and technologies including on-site access roads, switchgear, control and monitoring equipment, underground cabling and overhead distribution lines;

all in accordance with the Application.

All other Terms and Conditions remain the same.

This Notice shall constitute part of the approval issued under Approval No. 2189-8NQPZ5 dated December 19, 2011.

NOTICE REGARDING HEARINGS

In accordance with Section 139 of the Environmental Protection Act, within 15 days after the service of this notice, you may by further written notice served upon the Director, the Environmental Review Tribunal and the Environmental Commissioner, require a hearing by the Tribunal.

In accordance with Section 47 of the Environmental Bill of Rights, 1993, the Environmental Commissioner will place notice of your request for a hearing on the Environmental Registry.

Section 142 of the Environmental Protection Act provides that the notice requiring the hearing shall state:

- 1. The portions of the renewable energy approval or each term or condition in the renewable energy approval in respect of which the hearing is required, and;
- 2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The signed and dated notice requiring the hearing should also include:

- 3. The name of the appellant;
- 4. The address of the appellant;
- 5. The renewable energy approval number;
- 6. The date of the renewable energy approval;
- 7. The name of the Director;
- 8. The municipality or municipalities within which the project is to be engaged in;

This notice must be served upon:

The Secretary*
Environmental Review Tribunal
655 Bay Street, 15th Floor
Toronto, Ontario
M5G 1E5

AND

The Environmental Commissioner
1075 Bay Street, 6th Floor
Suite 605
Toronto, Ontario
M5S 2B1

AND


The Director
Section 47.5, *Environmental Protection Act*
Ministry of the Environment
2 St. Clair Avenue West, Floor 12A
Toronto, Ontario
M4V 1L5

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 314-4600, Fax: (416) 314-4506 or www.ert.gov.on.ca**

Under Section 142.1 of the Environmental Protection Act, residents of Ontario may require a hearing by the Environmental Review Tribunal within 15 days after the day on which notice of this decision is published in the Environmental Registry. By accessing the Environmental Registry at www.ebr.gov.on.ca, you can determine when this period ends.

Approval for the above noted renewable energy project is issued to you under Section 47.5 of the Environmental Protection Act subject to the terms and conditions outlined above.

DATED AT TORONTO this 15th day of November, 2013



Vic Schroter, P.Eng.
Director
Section 47.5, *Environmental Protection Act*

MK/
c: Area Manager, MOE Cornwall
c: District Manager, MOE Ottawa
Glen Tomkinson, South Glengarry General Partner 1 Inc. and South Glengarry General Partner 2 Inc.
operating as South Glengarry Solar Farm Partnership