

AMENDMENT TO RENEWABLE ENERGY APPROVAL

NUMBER 0905-8S7M96 Issue Date: March 4, 2014

Hamilton General Partner 1 Inc. and Hamilton General Partner 2 Inc. operating as Hamilton Solar Farm Partnership 620 Righters Ferry Rd Bala Cynwyd, Pennsylvania USA 19004

Site Location: Hamilton_Port Hope-4 Solar Energy Facility

2700 Payne Road Lot 3, Concession 2

Hamilton Township, County of Northumberland K0K 1C0

You are hereby notified that I have amended Approval No. 0905-8S7M96 issued on May 16, 2012 for a Class 3 solar project, as follows:

A. The definitions of "Acoustic Assessment Report" and "Application" in the Approval are deleted and replaced by the following.

- 1. "Acoustic Assessment Report" means the report included in the Application and entitled Acoustic Assessment Report Penn Energy-Hamilton Port Hope 4 Solar Farm, County of Northumberland, Ontario, dated August 28, 2013, prepared by HGC Engineering and signed by Petr Chocensky PhD and Ian Bosma, P.Eng.;
- 7. "Application" means the application for a Renewable Energy Approval dated July 12, 2011 and signed by Glen Tomkinson, Project Manager/ REA Coordinator, Penn Energy Renewables, Ltd., and all supporting documentation submitted with the application, including amended documentation submitted up to May 9, 2012; and as further amended by the application for a Renewable Energy Approval dated October 4, 2012 and signed by Glen Tomkinson, Project Manager/ REA Coordinator, Penn Energy Renewables, Ltd., and all supporting documentation submitted with the application, including amended documentation submitted up to October 15, 2012; and as further amended by the application for a Renewable Energy Approval dated October 9, 2013 and signed by Glen Tomkinson, Project Manager/ REA Coordinator, on behalf of Hamilton General Partner 1 Inc. and Hamilton General Partner 2 Inc. operating as Hamilton Solar Farm Partnership, and all supporting documentation submitted with the application, including amended documentation submitted up to February 25, 2014.
- B. Schedule B of the Approval is deleted and replaced by the following:

Coordinates of the Equipment are listed below in UTM17-NAD83 projection:

Source ID	Sound Power Level [dBA re 10 ⁻¹² W]	UTM Coordinates [m]		
		Easting	Northing	Source Description
NS-01	91	730,427	4,878,699	Array Inverter
NS-02	91	730,602	4,878,756	Array Inverter
NS-03	91	730,671	4,878,496	Array Inverter
NS-04	91	730,658	4,878,316	Array Inverter
NS-05	91	730,706	4,878,364	Array Inverter
NS-06	91	730,763	4,878,212	Array Inverter
NS-07	91	730,903	4,877,955	Array Inverter
NS-08	91	730,937	4,877,746	Array Inverter
NS-09	91	730,871	4,877,689	Array Inverter
NS-10	91	730,921	4,877,557	Array Inverter
NS-11	69	730,432	4,878,699	Array Transformer
NS-12	69	730,607	4,878,756	Array Transformer
NS-13	69	730,673	4,878,496	Array Transformer
NS-14	69	730,663	4,878,316	Array Transformer
NS-15	69	730,702	4,878,364	Array Transformer
NS-16	69	730,759	4,878,212	Array Transformer
NS-17	69	730,898	4,877,955	Array Transformer
NS-18	69	730,933	4,877,747	Array Transformer
NS-19	69	730,876	4,877,689	Array Transformer
NS-20	69	730,926	4,877,556	Array Transformer
NS-21	88	730,748	4,878,623	Transformer 10 MVA

Note: A five (5) dB tonal penalty is included in the above sound power levels.

All other Terms and Conditions of the Approval remain the same.

This Notice shall constitute part of the approval issued under Approval No. 0905-8S7M96 dated May 16, 2012

In accordance with Section 139 of the <u>Environmental Protection Act</u>, within 15 days after the service of this notice, you may by further written notice served upon the Director, the Environmental Review Tribunal and the Environmental Commissioner, require a hearing by the Tribunal.

In accordance with Section 47 of the <u>Environmental Bill of Rights, 1993</u>, the Environmental Commissioner will place notice of your request for a hearing on the Environmental Registry.

Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing shall state:

- 1. The portions of the renewable energy approval or each term or condition in the renewable energy approval in respect of which the hearing is required, and;
- 2. The grounds on which you intend to rely at the hearing in relation to <u>each</u> portion appealed.

The signed and dated notice requiring the hearing should also include:

- 3. The name of the appellant;
- 4. The address of the appellant;
- 5. The renewable energy approval number;
- 6. The date of the renewable energy approval;
- 7. The name of the Director;
- 8. The municipality or municipalities within which the project is to be engaged in;

This notice must be served upon:

The Secretary* The Environmental Commissioner The Director Environmental Review Tribunal 1075 Bay Street, 6th Floor Section 47.5, Environmental Protection Act 655 Bay Street, 15th Floor Suite 605 Ministry of the Environment Toronto, Ontario Toronto, Ontario AND 2 St. Clair Avenue West, Floor 12A AND M5G 1E5 M5S 2B1 Toronto, Ontario M4V 1L5

* Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 314-4600, Fax: (416) 314-4506 or www.ert.gov.on.ca

Under Section 142.1 of the <u>Environmental Protection Act</u>, residents of Ontario may require a hearing by the Environmental Review Tribunal within 15 days after the day on which notice of this decision is published in the Environmental Registry. By accessing the Environmental Registry at www.ebr.gov.on.ca, you can determine when this period ends.

Approval for the above noted renewable energy project is issued to you under Section 47.5 of the <u>Environmental Protection Act</u> subject to the terms and conditions outlined above.

DATED AT TORONTO this 4th day of March, 2014

Vic Schroter, P.Eng.

Director

Section 47.5, Environmental Protection Act

MK/

c: District Manager, MOE Peterborough

Glen Tomkinson, Hamilton General Partner 1 Inc. and Hamilton General Partner 2 Inc. operating as Hamilton Solar Farm Partnership